

TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No.	90 002 - 73 HH
Company	Trafag AG Industriestraße 11 8608 Bubikon, SWITZERLAND
Product Description	Differential Pressure Switches
Type	920, 924, 932
Environmental Category	D, EMC1
Technical Data / Range of Application	Output: 1c/o - contact Contact rating: 15A, 250V AC (resistive load) Ranges (bar): -0.6 - 3.4 up to 0 - 16 Type-no.: 920/924/932 - 2374,- 2376,- 2377,- 2378,- 2379 920/924/932 - 2674,- 2676,- 2677,- 2678,- 2679 Degree of protection: IP 65
Test Standard	GL Guidelines for the Performance of Type Approvals, Chapter 2 – Test Requirements for Electrical / Electronic Equipment and Systems (VI-7-2), Edition 2012
Documents	Data sheet: H72253o Data sheets: E01764b, E01752a Drawing: D 93210
Remarks	This certificate is issued on the basis of GL Guidelines for the Performance of Type Approvals, Chapter 1 - Procedure (VI-7-1), Edition 2007

Valid until **2020-01-22**
Page **1 of 1**
File No. **I.D.01**
Hamburg, 2015-01-23

Type Approval Symbol




Marco Rinkel


Dariusz Lesniewski