

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 91 036 - 84 HH

Company Trafag AG
Industriestraße 11
8608 Bubikon, SWITZERLAND

Product Description Piston-Type Pressure Switch
Type Pressostat PK 944.23..., 944.26..., 947.23..., 947.26...

Environmental Category D, EMC1

Technical Data / Range of Application	Pressure ranges [bar]:	switching differential [bar]
	9xx.xx78: 1 - 10	0.45 - 0.9
	9xx.xx81: 4 - 40	1.8 - 3.4
	9xx.xx82: 6 - 60	2.3 - 4.8
	9xx.xx83: 10 - 100	3.2 - 7.5
	9xx.xx84: 16 - 160	4.1 - 11
	9xx.xx85: 25 - 250	6.0 - 19
	9xx.xx86: 40 - 400	7.5 - 28
	9xx.xx87: 60 - 600	9.0 - 38

944...: with display window, screw adjustment
947...: without display window, screw adjustment
Output: 1 floating c/o - contact
Rating: see manufacturer's data sheet
Degree of protection: IP 65

Test Standard Guidelines for the Performance of Type Approvals, Chapter, Edition 2012

Documents Data sheet: H72259n
Drawing: No. D-93001

Remarks None

Valid until 2019-03-26

Page 1 of 1

File No. I.D.01

Hamburg, 2014-03-27

Type Approval Symbol



Germanischer Lloyd

Marco Rinkel

Dariusz Lesniewski