

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No.	90 000 - 73 HH
Company	Trafag AG Industriestraße 11 8608 Bubikon, SWITZERLAND
Product Description	Pressure switch
Type	900-..., 903-..., 904-..., 907-..., 912-..., 915-..., 940-..., 941-..., 942-...
Environmental Category	D, EMC1
Technical Data / Range of Application	Type - no.: 9..-2376, -2377, -2378, -2379, -2380, -2381 9..-2672, -2673, -2675, -2676, -2677, -2678, -2679, -2680, -2681 Type - no.: 9.. -23G6, -23G8, -23G9, -23H1, -23H3 Output: 1 c/o - contact Contact rating: see manufacturer's data sheet With adjustable switching differential: types 903-..., 907-..., 915-... 940-..., 941-..., 942-... Ranges: -0.9...1.5 bar to 4...40 bar 5...50 psi to 125...1500 psi Degree of protection: IP 65
Test Standard	Guidelines for the Performance of Type Approvals, Chapter 2, Edition 2003
Documents	Data sheets: H72252n, H72257n Drawings: D93208(a), D93209(a) Drawings: D43003(b)...D43005(b), D43006(a)...D43017(a) Test Reports: V 501/30.05.95, V 524/3.08.95
Remarks	None

Valid until 2019-03-26

Page 1 of 1

File No. I.D.01

Hamburg, 2014-03-27

Type Approval Symbol



Germanischer Lloyd

Marco Rinkel

Dariusz Lesniewski

This certificate is issued on the basis of "Guidelines for the Performance of Type Approvals Part 1, Procedure".