


Type Approval Certificate Extension

This is to certify that Certificate No. 06/20045 for the undernoted products is amended and renumbered as shown.

This certificate is issued to:

PRODUCER	Trafag AG
PLACE OF PRODUCTION	Industriestrasse 11 8608 Bubikon Switzerland
DESCRIPTION	Pressure transmitter NAE
TYPE	8255.①.23②.③.19 ① = Pressure range: 75, 76, 77, 78, 79, 80, 81, 82, 83, 85, 74, 84, 86 (0...2.5 to 0...600 bar) ② = Pressure connection: 17, 18, 30 ③ = Execution: 01, 32, 35
APPLICATION	Marine, offshore and industrial applications for use in environmental categories ENV1, ENV2, ENV3 and ENV4 as defined in Lloyd's Register's Type Approval System, Test Specification Number 1 - 2002.
ADDITIONAL TESTS	Dry heat (125°C / 16hrs) Low temperature (-40°C / 16hrs) Vibration test (40g / 5 to 2000Hz) Enclosure IP 65/ 67 (③ = 32, 35) IP 65 (③ = 01)
DESIGN CODE	Manufacturer's specification
Certificate No.	06/20045 (E1)
Issue Date	13 March 2012
Expiry Date	09 November 2016
Sheet	1 of 2


for Thorsten Wolff
Hamburg Design Support Centre
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS


OTHER CONDITIONS Limitations of measuring accuracy are to be obtained from the manufacturer's data sheet.

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No. ETS 26202-12 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No. 06/20045 to which this extension should be attached.

Certificate No.	06/20045 (E1)
Issue Date	13 March 2012
Expiry Date	09 November 2016
Sheet	2 of 2



Thorsten Wolff
Hamburg Design Support Centre
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS